

*ОАО Российский Концерн по Производству
Электрической и Тепловой Энергии на
Атомных Станциях*
(ОАО Концерн Росэнергоатом)

Attn: ОАО Концерн Росэнергоатом
Deputy Director General – NPP
Operations and Operation Director
A. V. Shutikov

***Balakovskaya NPP, branch office of
ОАО Концерн Росэнергоатом***

06.02.2013 No. ИИП-13/14/1917

for No. 9/04/431-BH dd 30.01.2013

VB

9/04/2014

Dear Aleksandr Viktorovich,

This is to inform you that since 2008, *Balakovskaya* NPP Units Nos. 1-4 have been installing shutoff devices (drawing No. 484SB) in “hot” and “cold” primary circuit headers of *ИГБ-1000М*-series steam generators during PPMs. Such shutoff devices can only be installed using polar cranes due to the fact that crossarms for installation of these plugs into steam generator headers are over 7 (seven) meters long. O-rings and gaskets made of *51-1562 Pað TV 38 1051325* or *51-1786 Pað TV 2531-002-28943826* rubber can be stored for up 1 (one) year. We have not experienced problems with primary circuit leaks when using said devices.

Chief Engineer



V. N. Bessonov

Timokhin Vladimir Ivanovich
Centralized Repairs Shop
S. I. Kamnev 88453-499396

Translated by:
Ferreyro F. P. E.

Please refer to our letter No. and date when answering