OAO Rossiysky Kontsern po Proizvodstvu Elektricheskoy y Teplovoy Energii na Atomnykh Stantsiyakh Attn: Deputy Director General – NPP Operations and Operation Director A. V. Shutikov

Kalininskaya NPP, branch office of OAO Kontsern Rosenergoatom

14.02.2013 No. 41-18/3007

for No. 9/04/431-вн dd 30.01.2013

**Subject: Experience Using Shutoff Devices** 

As a response to your request regarding use of shutoff devices for  $\Pi\Gamma B$ -1000M-series steam generators, we are informing you that the *Kalininskaya* NPP does not have much experience using such devices. However, the experience we do have suggests that these devices work as intended throughout repair campaigns.

As for drawbacks, they are hard to install/dismantle, require use of polar cranes, and cause problems due to the need to find place for and store big sets of shutoff devices and special tools in the central hall during PPMs.

Chief Engineer

I. N. Bogomolov

РЦ-2, Сироткин (48255) 6-95-35