



RUSATOMSERVICE

RUSATOM SERVICE JSC  
+7 (495) 995 7680  
info@rusatomservice.ru

02 ИЮЛ 2018

№

309/03-01/4242

your ref. № \_\_\_\_\_ date \_\_\_\_\_

Mr. H. Ghaffari  
Manager and Managing Director  
The Bushehr Nuclear Power Plant

Copy to NPPD

On acceptance of the sealing rings  
produced by JSC CKBA

Dear Mr. Ghaffari,

With reference to complaints against quality of shipped sealing rings produced by JSC CKBA we send you spare part drawings containing information on acceptable variation of working surface design and number of joints. Please find enclosed drawings of the following spare parts:

- ЦКБ K99195-500 Г.02 (1-C06.21-045.0023, 1-C06.21-046.0015).
- ЦКБ K99502-500.08 (1-C06.21-003.0018).
- ЦКБ K99516-700 Б.01 (1-C06.21-044.0021).

According to the technical requirements of the drawings:

- i.3 – maximum 0.5 mm of variation of high and low levels is allowed; for joint marks – maximum 1 mm.; for press mould and machining marks - maximum 0.5 mm more than tolerable space per section is allowed.
- i.4 – maximum 3 joints allowed.

The Supplier guarantees their implementing in accordance with the technical documentation.

Based on the abovementioned, we ask you to accept the Goods and approve the relevant Incoming control act.

Attachment:

1. Spare part drawing ЦКБ K99195-500 Г.02.
2. Spare part drawing ЦКБ K99502-500.08.
3. Spare part drawing ЦКБ K99516-700 Б.01.
4. Guarantee letter from CKBA No.2096/03/133 dated 28.06.2018.

Project Manager

Vladimir Bozrikov

Denis Boldin

+7(495)995 76 80, ext. 286

